

National Supervision and Inspection Center for Explosion Protection and Safety of Instrumentation (NEPSI)

Ex marking: [Ex ia Ga] ⅡC

[Ex ia Da] C

Um: 250V

Certified parameters (Terminals 1, 2, 3):

Uo=8.7V, Io=33mA, Po=72mW

ⅡC: Co=5εF, Lo=28mH

C(ⅡB): Co=49εF, Lo=84mH